


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 126.99 lm/W			
MODEL	IL-PD595US 3.500K	Imax(cd)	1936	S/MH(C0/180)	1.24
NOMINAL POWER(W)	30	LOR(%)	100.0	S/MH(C90/270)	1.22
RATED VOLTAGE(V)	230	TOTAL FLUX(lm)	3808.3	η UP,DN(C0-180)	0.0,49.7
NOMINAL FLUX(lm)	3808.34	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,50.3
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	230	η down(%)	100.0	CIBSE SHR MAX	1.25

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



β H() Range:-90 - 90DEG
 β H() Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	$\%lum, lamp$
10	1896	1883	1887	1884	1904	1886	1890	1885	0- 10	182.0	182.0	4.78,4.78
20	1794	1799	1782	1797	1808	1802	1790	1803	10- 20	521.9	703.9	18.5,18.5
30	1590	1543	1620	1550	1624	1562	1636	1559	20- 30	783.3	1487	39.1,39.1
40	1141	1114	1122	1141	1200	1159	1137	1143	30- 40	861.6	2349	61.7,61.7
50	505.5	578.5	703.0	587.6	550.9	606.9	717.6	580.3	40- 50	653.0	3002	78.8,78.8
60	210.5	325.5	363.3	312.9	226.2	334.0	376.3	306.6	50- 60	393.5	3395	89.2,89.2
70	148.5	210.2	217.7	204.4	142.2	213.2	220.3	200.6	60- 70	236.7	3632	95.4,95.4
80	109.2	95.74	0	91.44	108.3	95.18	0	98.63	70- 80	154.1	3786	99.4,99.4
90	1.380	0	0	0	2.021	0	0	0	80- 90	22.23	3808	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

$H(\beta)$ Range:-90 - 90DEG
 $\beta H()$ Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2023-08-14

V(B) Range:-75 - 75DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
 Humidity:65.0%
 Test Distance:8.240m [K=1.0000]
 Remarks: IL-PD595US 3.500K

LUMINANCE LIMITATION CURVES

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:



LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	1520	0
80	2079	0
75	1745	1838
70	1436	2104
65	1246	2276
60	1392	2402
55	1897	3079
50	2600	3615
45	3702	4084


β H() Range:-90 - 90DEG
 β H() Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.07	1.03	1.00	1.05	1.01	.98	1.00	.98	.95	.97	.94	.93	.93	.91	.90	.88
2.0	.95	.90	.85	.94	.88	.84	.90	.86	.82	.87	.83	.80	.84	.81	.78	.76
3.0	.86	.79	.73	.84	.78	.73	.81	.76	.71	.79	.74	.70	.76	.72	.69	.67
4.0	.77	.70	.64	.76	.69	.64	.74	.68	.63	.72	.66	.62	.69	.65	.61	.59
5.0	.70	.62	.57	.69	.62	.56	.67	.61	.56	.65	.60	.55	.64	.59	.55	.53
6.0	.64	.56	.50	.63	.56	.50	.62	.55	.50	.60	.54	.49	.58	.53	.49	.47
7.0	.59	.51	.45	.58	.51	.45	.57	.50	.45	.55	.49	.45	.54	.48	.44	.43
8.0	.54	.46	.41	.53	.46	.41	.52	.46	.41	.51	.45	.41	.50	.44	.40	.39
9.0	.50	.43	.37	.49	.42	.37	.48	.42	.37	.47	.41	.37	.46	.41	.37	.35
10.0	.46	.39	.34	.46	.39	.34	.45	.39	.34	.44	.38	.34	.43	.38	.34	.32



βH() Range:-90 - 90DEG
βH() Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

WEC AND CCEC

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)										
0.0																	
1.0	.254	.144	.046	.247	.141	.045	.234	.134	.043	.222	.128	.041	.211	.122	.039		
2.0	.243	.133	.041	.237	.131	.040	.226	.126	.039	.216	.121	.038	.206	.117	.037		
3.0	.229	.122	.037	.224	.120	.036	.214	.116	.035	.205	.112	.034	.196	.109	.034		
4.0	.215	.112	.033	.210	.110	.033	.201	.107	.032	.193	.104	.031	.186	.101	.031		
5.0	.201	.103	.030	.197	.101	.029	.190	.099	.029	.182	.096	.029	.176	.094	.028		
6.0	.189	.095	.027	.185	.094	.027	.179	.092	.027	.172	.089	.026	.166	.087	.026		
7.0	.178	.088	.025	.175	.087	.025	.168	.085	.025	.163	.083	.024	.157	.082	.024		
8.0	.168	.082	.023	.165	.081	.023	.159	.080	.023	.154	.078	.023	.149	.077	.022		
9.0	.158	.077	.021	.156	.076	.021	.151	.075	.021	.146	.073	.021	.142	.072	.021		
10.0	.150	.072	.020	.148	.071	.020	.143	.070	.020	.139	.069	.020	.135	.068	.020		

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.176	.157	.139	.151	.134	.119	.103	.092	.083	.059	.054	.048	.019	.017	.016		
2.0	.166	.132	.104	.142	.114	.090	.097	.079	.063	.056	.046	.037	.018	.015	.012		
3.0	.157	.114	.080	.134	.098	.069	.092	.068	.049	.053	.040	.029	.017	.013	.009		
4.0	.148	.100	.063	.127	.087	.055	.088	.060	.039	.051	.035	.023	.016	.012	.008		
5.0	.141	.089	.051	.121	.077	.045	.083	.054	.032	.048	.032	.019	.016	.010	.006		
6.0	.134	.081	.043	.115	.070	.037	.079	.049	.026	.046	.029	.016	.015	.009	.005		
7.0	.127	.074	.036	.110	.064	.031	.076	.045	.022	.044	.026	.013	.014	.009	.004		
8.0	.122	.068	.031	.105	.059	.027	.072	.041	.019	.042	.024	.011	.014	.008	.004		
9.0	.116	.063	.027	.100	.055	.024	.069	.038	.017	.040	.023	.010	.013	.007	.003		
10.0	.111	.059	.024	.096	.051	.021	.066	.036	.015	.039	.021	.009	.013	.007	.003		

pH() Range:-90 - 90DEG
 pH() Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2023-08-14

V(B) Range:-75 - 75DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
 Humidity:65.0%
 Test Distance:8.240m [K=1.0000]
 Remarks: IL-PD595US 3.500K

UGR(Unified Glare Rating) Table

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm										
NAME: IL-PD595US 3.500K					TYPE:			WEIGHT:		
SPEC.:					DIM.:			SERIAL No.:		
MFR.: EVERFINE					SUR.:550*550			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	15.2	16.5	15.4	16.7	16.9	15.3	16.6	15.5	16.8	17.0
3H	15.9	17.1	16.1	17.3	17.5	16.2	17.5	16.5	17.7	17.9
4H	16.3	17.5	16.6	17.7	18.0	16.8	17.9	17.1	18.2	18.4
6H	16.8	17.9	17.1	18.2	18.4	16.8	17.9	17.1	18.2	18.4
8H	17.0	18.0	17.3	18.3	18.6	16.8	17.8	17.1	18.1	18.4
12H	17.1	18.1	17.4	18.4	18.7	16.7	17.7	17.1	18.0	18.3
4H 2H	15.5	16.6	15.8	16.9	17.1	15.5	16.7	15.8	16.9	17.1
3H	16.6	17.6	16.9	17.9	18.1	16.6	17.6	17.0	17.9	18.2
4H	17.2	18.2	17.6	18.5	18.8	17.3	18.2	17.7	18.6	18.9
6H	17.9	18.7	18.3	19.0	19.4	17.4	18.3	17.8	18.6	19.0
8H	18.1	18.8	18.5	19.2	19.6	17.4	18.1	17.8	18.5	18.9
12H	18.2	18.9	18.7	19.3	19.7	17.4	18.0	17.8	18.4	18.8
8H 4H	17.5	18.3	17.9	18.6	19.0	17.6	18.4	18.0	18.7	19.1
6H	18.4	19.0	18.8	19.4	19.8	17.8	18.4	18.2	18.8	19.2
8H	18.7	19.3	19.2	19.7	20.1	17.7	18.3	18.2	18.7	19.2
12H	18.9	19.4	19.4	19.9	20.3	17.7	18.2	18.2	18.6	19.1
12H 4H	17.5	18.2	17.9	18.6	19.0	17.7	18.3	18.1	18.7	19.1
6H	18.4	18.9	18.8	19.3	19.8	17.8	18.4	18.3	18.8	19.2
8H	18.7	19.2	19.2	19.6	20.1	17.8	18.3	18.3	18.7	19.2
Variations with the observer position at spacings:										
S = 1.0H	+ 0.4 / - 0.6					+ 0.4 / - 0.5				
1.5H	+ 0.4 / - 0.7					+ 0.6 / - 0.9				
2.0H	+ 0.9 / - 1.2					+ 1.2 / - 1.5				

CIE Pub.117, 3808 lm Total Lamp Luminous Flux Corrected ($8\log(F/F_0) = 4.6$)

β_H () Range:-90 - 90DEG
 β_H () Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2023-08-14

V(B) Range:-75 - 75DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
 Humidity:65.0%
 Test Distance:8.240m [K=1.0000]
 Remarks: IL-PD595US 3.500K

UTILIZATION FACTORS TABLE

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	68	58	52	67	58	52	66	57	52	46
0.80	77	68	62	76	67	61	75	67	61	55
1.00	85	76	70	84	75	70	82	76	69	63
1.25	91	82	77	90	82	76	87	80	76	69
1.50	95	87	82	94	86	81	91	85	80	74
2.00	101	94	89	99	93	88	96	91	86	80
2.50	104	97	93	102	96	92	98	94	90	82
3.00	106	101	96	104	99	95	100	96	93	85
4.00	109	105	101	107	103	100	103	100	97	89
5.00	111	107	104	109	105	103	105	102	100	91
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

$H(\beta)$ Range:-90 - 90DEG
 $\beta H()$ Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2023-08-14

$V(B)$ Range:-75 - 75DEG
 $V(B)$ Interval: 5.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
 Humidity:65.0%
 Test Distance:8.240m [K=1.0000]
 Remarks: IL-PD595US 3.500K

ISOCANDELA DIAGRAM

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:




β H() Range:-90 - 90DEG
 β H() Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

AAI Figure

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

β H() Range:-90 - 90DEG
 β H() Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2023-08-14

V(B) Range:-75 - 75DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
 Humidity:65.0%
 Test Distance:8.240m [K=1.0000]
 Remarks: IL-PD595US 3.500K

ISOLUX DIAGRAM

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:



β H() Range:-90 - 90DEG
 β H() Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

LED Avg.L Report

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	1259
L_0~180(75)av	1721
L_0~180(85)av	1753
L_90~270(65)av	2309
L_90~270(75)av	1837
L_90~270(85)av	0
L_45(65)av	2006
L_45(75)av	2079
L_45(85)av	0

Standard: GB/T 29293-2012

β H() Range:-90 - 90DEG
 β H() Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

Planar Illuminance Curve



β H() Range:-90 - 90DEG
 β H() Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:

Table--1

UNIT: cd

[illegible]

```

pH( ) Range:-90 - 90DEG
pH( ) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

```

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:

UNIT: cd

[illegible]

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:

Table--3

UNIT: cd

[illegible]

```

pH( ) Range:-90 - 90DEG
pH( ) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

```

```
V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K
```

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:230.31V I:0.1334A P:29.990W PF:0.9762 Freq:49.99Hz Lamp Flux:3808.34x1 lm		
NAME: IL-PD595US 3.500K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EVERFINE	SUR.:550*550	Shielding Angle:

Table--4

UNIT: cd

[illegible]

```

pH( ) Range:-90 - 90DEG
pH( ) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2023-08-14

```

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.404.7
Humidity:65.0%
Test Distance:8.240m [K=1.0000]
Remarks: IL-PD595US 3.500K